

Emblem

'The official language is the mother tongue'

C No. 307/2023

Fire and Rescue Station

Kayamkulam Date: 17.5.2023

Phone: 0479-2442101

email. kym.frs@kerala.gov.in

Station Officer

Kayamkulam

Manager

Gayathri Central School

Kayamkulam

Sir,

Subject:-Fire Station Kayamkulam Gayatri Central School-Building  
Construction.NOC-Regarding return of application

Reference- (1) Hon'ble Government Order No. 78/2019/LSGD dated 02.11.2019.

(2) Your application submitted to the station on 16.05.2023

As per Reference (2), upon examination of the application submitted by you at the station, it was found that the height of your building is less than 15 meters and the area of the foundation is less than 1000 square meters. Therefore, as per indication (1), no objection certificate is required from the Fire Department for granting permit for educational buildings up to 1000 square meters as per the Kerala Panchayath Building Construction Rules 2012, your application and the attached documents are returned. It is also informed that the fire safety systems installed in your building (Appendix-L) should be functional in the inspection conducted by the station.



*True translation  
of the original*

*Reena*  
*31/12/2025*

**REENA GOPINATH**  
**ADVOCATE & NOTARY**  
**KAYAMKULAM**  
**ALAPPUZHA DISTRICT**

Station Officer,

Fire Rescue Station,

Kayamkulam-690 582,